

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

NEW DELHI-110001

No.F6/DFS/MS/School/2022/SZ/848

Dated: 03/08/2022


FIRE SAFETY CERTIFICATE

Certified that the New Holy Public School, Shish Ram Park, Bindapur Road, Uttam Nagar, New Delhi-59, comprised of ground plus four upper floors, owned/occupied by New Holy Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2010/2549 Dated 01/09/2010. The school building was re-inspected by the officer concerned of this department on dated 22/07/2022 in the presence of Sh. Ajay Arora (Chairman) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 35 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....03/08/2022... at New Delhi.



VICE PRINCIPAL
NEW HOLY PUBLIC SCHOOL
(Recognised & Affiliated to C.B.S.E.)
Sis Ram Park, Uttam Nagar, N.D.-59



(Sunil Chawdhary)
Dy. Chief Fire Officer
Manager
NEW HOLY PUBLIC SCHOOL
(Recognised & Affiliated to C.B.S.E.)
Sis Ram Park, Uttam Nagar, N.Delhi-59

Copy to:-

1. The Principal,
New Holy Public School, Shish Ram Park, Bindapur Road, Uttam Nagar, New Delhi-59.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.